

AD-A147 481 NONCONTACT PHOTO THERMAL PROBE BEAM DEFLECTION 1/1  
MEASUREMENT OF THERMAL DIF..(U) IBM RESEARCH LAB SAN  
JOSE CA J C LOUIERGUE ET AL. 17 OCT 84 RJ-4472 (48260)  
UNCLASSIFIED N00014 R3 C 0170 F/G 20/5 NL


END

DATE

FILMED

12-84

DTIC



MICROCOPY RESOLUTION TEST CHART  
NATIONAL BUREAU OF STANDARDS-1963-A

RJ 4472 (48260) 10/17/84  
Physics

12

# Research Report

NONCONTACT PHOTO-THERMAL PROBE-BEAM DEFLECTION MEASUREMENT  
OF THERMAL DIFFUSIVITY IN AN UNCONFINED HOT GAS

J. C. Loulergue  
A. C. Tam

IBM Research Laboratory  
San Jose, California 95193

AD-A147 481

DTIC  
ELECTE  
NOV 13 1984  
S D  
E

~~RESTRICTED DISTRIBUTION NOTICE~~

This report has been submitted for publication outside of IBM and will probably be copyrighted if accepted for publication. It has been issued as a Research Report for early dissemination of its contents. In view of the transfer of copyright to the outside publisher, its distribution outside of IBM prior to publication should be limited to peer communications and specific requests. After outside publication, requests should be filled only by reprints or legally obtained copies of the article (e.g., payment of royalties).



Research Division  
Yorktown Heights, New York • San Jose, California • Zurich, Switzerland

This document has been approved  
for public release and sales its  
distribution is unlimited.

84 11 05 101

DTIC FILE COPY

Copies may be requested from:  
IBM Thomas J. Watson Research Center  
Distribution Services  
Post Office Box 218  
Yorktown Heights, New York 10598

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER 13	2. GOVT ACCESSION NO.	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) Noncontact photo-thermal probe-beam deflection measurement of thermal diffusivity in an unconfined hot gas.		5. TYPE OF REPORT & PERIOD COVERED Technical Report
7. AUTHOR(s) J.C. Loulergue A.C. Tam		6. PERFORMING ORG. REPORT NUMBER
9. PERFORMING ORGANIZATION NAME AND ADDRESS International Business Machines, Corp. 5600 Cottle Rd., San Jose, CA 95193		8. CONTRACT OR GRANT NUMBER(s) N00014-83-C-0170
11. CONTROLLING OFFICE NAME AND ADDRESS Office of Naval Research 800 N. Quincy St., Arlington, VA 22217		10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS NR633-844
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)		12. REPORT DATE 10/18/84
		13. NUMBER OF PAGES 11
		15. SECURITY CLASS. (of this report)
		15a. DECLASSIFICATION/DOWNGRADING SCHEDULE
16. DISTRIBUTION STATEMENT (of this Report)  This document has been approved for public release and sale; its distribution is unlimited.		
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
18. SUPPLEMENTARY NOTES  To be published in Applied Physics Letters		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number)  Photo-thermal, thermal diffusivity gas, laser application, temperature, flame diagnostics. <i>-carbon dioxide</i>		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number)  A pulsed <del>CO<sub>2</sub></del> laser beam is used to produce a transient thermal refractive-index-gradient in nitrogen gas doped with trace amounts of absorbing Freon 12 at temperatures from 25°C to 425°C. The diffusion of this gradient is probed by a continuous HeNe laser beam parallel but displaced from the pulsed beam. The observed deflection signal agrees well with the theory of Jacson et al. (1981), and signal. ↑		

DD FORM 1 JAN 73 1473

EDITION OF 1 NOV 65 IS OBSOLETE  
S/N 0102-LF-014-6601

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

965 IBM 18

965 IBM 18

OFFICE OF NAVAL RESEARCH

Contract N00014-83-C0170

Task No. 633-844

TECHNICAL REPORT No. 13

Noncontact photo-thermal probe-beam defection measurement  
of thermal diffusivity in an unconfined hot gas.

By

J. C. Loulergue

A. C. Tam

IBM Research Laboratory  
San Jose, California

Reproduction in whole or in part is permitted for  
any purpose of the United States Government

This document has been approved for public  
release and sale, its distribution is unlimited

965 · IBM · 18

DL/413/83/01  
GEN/413-2

TECHNICAL REPORT DISTRIBUTION LIST. GEN

	No.		No.
Office of Naval Research Attn: Code 413 800 N. Quincy Street Arlington, VA 22217	2	Naval Ocean Systems Center Attn. Technical Library San Diego, California 92152	1
Dr. Harold E. Guard Dept. of the Navy Office of Naval Research Arlington, VA 22217	1	Naval Weapons Center Attn: Dr. A. B. Amster Chemistry Division China Lake, California 93555	1
Commander, Naval Air Systems Command Attn: Code 310C (H. Rosenwasser) Washington, DC 20360	1	Scientific Advisor Commandant of the Marine Corps Code RD-1 Washington, DC 30280	1
Naval Civil Engineering Laboratory Attn: Dr. R. W. Drisko Port Hueneme, CA 93401	1	Dean William Tolles Naval Postgraduate School Monterey, CA 93940	1
Superintendent Chemistry Division, Code 6100 Naval Research Laboratory Washington, DC 20375	1	U. S. Army Research Office Attn: CRD-AA-IP P. O. Box 12211 Research Triangle Park, NC 27709	1
Defense Technical Information Center Building 5, Cameron Station Alexandria, Virginia 22314	12	Mr. Vincent Schaper DTNSRDC Code 2830 Annapolis, Maryland 21402	1
DTNSRDC Attn: Dr. G. Bosmajian Applied Chemistry Division Annapolis, Maryland 21401	1	Mr. John Boyle Materials Branch Naval Ship Engineering Center Philadelphia, Pennsylvania 19112	1
Naval Ocean Systems Center Attn: Dr. S. Yamamoto Marine Sciences Division San Diego, California 91232	1	Mr. A. M. Anzalone Administrative Librarian PLASTEC/ARRADCOM Bldg. 3401 Dover, New Jersey 07801	1

965 IBM 18

DL/413/83/01  
633/413-2

TECHNICAL REPORT DISTRIBUTION LIST, 633

Dr. Henry Freiser  
Chemistry Department  
University of Arizona  
Tucson, AZ 85721

Dr. Gregory D. Botsaris  
Department of Chemical Engineering  
Tufts University  
Medford, MASS 02155

Dr. J. H. Hargis  
Department of Chemistry  
Auburn University  
Auburn, ALA 36849

Dr. Ronald S. Sheinson  
Code 6180  
Naval Research Laboratory  
Washington, DC 20375

Dr. Edward J. Poziomek  
Chief, Research Division  
Chemical Research and  
Development Center  
ATTN: DRDAR-CLB  
Aberdeen Proving Ground, MD 21010

Dr. Lynn Jarvis  
Code 6170  
Naval Research Laboratory  
Washington, DC 20375

Dr. Richard Hollins  
Code 385  
Naval Weapons Center  
China Lake, CA 93555

Dr. Christie G. Enke  
Department of Chemistry  
Michigan State University  
East Lansing, MICH 48824

Dr. Timothy L. Rose  
EIC Laboratories, Inc.  
111 Chapel Street  
Newton, Massachusetts 02158

965 IBM 18



RJ 4472 (48260) 10/17/84

Physics

**NONCONTACT PHOTO-THERMAL PROBE-BEAM DEFLECTION MEASUREMENT  
OF THERMAL DIFFUSIVITY IN AN UNCONFINED HOT GAS**

J. C. Loulergue\*

A. C. Tam

IBM Research Laboratory  
San Jose, California 95193

**ABSTRACT:** A pulsed CO<sub>2</sub> laser beam is used to produce a transient thermal refractive-index-gradient in nitrogen gas doped with trace amounts of absorbing Freon 12 at temperatures from 25°C to 425°C. The diffusion of this gradient is probed by a continuous HeNe laser beam parallel but displaced from the pulsed beam. The observed deflection signal agrees well with the theory of Jackson *et al.* (1981), and thermal diffusivity or gas temperature can be derived from the signal.

\*On leave from Institut d'Optique Théorique et Appliquée, Centre  
Universitaire d'Orsay, B. P. No. 43, 91406 Orsay Cedex, France.

Accession For	
NTIS GRA&I	<input checked="checked" type="checkbox"/>
DTIC TAB	<input type="checkbox"/>
Unannounced	<input type="checkbox"/>
Justification	
By	
Distribution/	
Availability Codes	
Dist	Avail and/or Special
A-1	



The Photo-Thermal Probe-beam Deflection (PTPD) method developed by Boccaro and co-workers<sup>1-5</sup> has gained much attention recently as a noncontact spectroscopic measurement tool in gases as well as in condensed matter. PTPD relies on the generation of a thermal Refractive-Index-Gradient (RIG) in or near a sample due to the absorption of a "pump" beam, and the detection of this RIG by a continuous probe beam. In most PTPD work,<sup>1-8</sup> the pump beam is a continuous modulated laser beam obtained by chopping at tens of Hz, and the probe beam deflection is modulated correspondingly. However, Rose *et al.*<sup>9</sup> have recently used a pulsed laser for PTPD spectroscopy in a flame. The advantages of using pulsed laser are that much higher power is available and also measurements related to a transient thermal RIG can be made.

We have made a first experimental investigation of the evolution of the transient thermal RIG produced by a pump laser pulse and detected by a spatially separated probe beam. Unlike the previous PTPD investigations which are mainly spectroscopic, we show here that thermal diffusivity  $D$  or gas temperature can be obtained by analyzing the time-dependent PTPD signal shape. This provides a new method for noncontact monitoring of temperature or material composition that affect  $D$ . The present experiment is designed to measure the thermal RIG in an unconfined hot gas to mimic an open flame. It should be noted that a pulsed laser can also generate an acoustic RIG in a flame observable with probe-beam deflection.<sup>10</sup>

Our experimental apparatus is indicated in Fig. 1. The gas cell is made from a block of aluminum alloy of dimension about 5 cm  $\times$  4 cm  $\times$  1.8 cm. Suitable cavities are made in the aluminum block to allow cartridge heaters to be inserted for heating of the gas. Two open windows of dimension 2 mm  $\times$  5 mm allow the entrance and exit of the laser beams. A slow stream of nitrogen with 0.11% Freon 12 (pre-mixed gas from

Matheson) flows into the aluminum cell. The purpose of the low concentration of Freon is to provide some weak absorption of the pump beam, which is a  $\text{CO}_2$  laser beam at  $10.834 \mu\text{m}$ , with pulse width  $150 \mu\text{sec}$  and peak power 50 Watt at 30 Hz repetition rate. The gas flow rate is smaller than  $10^{-2} \text{ cc/sec}$  to ensure that the gas temperature in the measurement chamber is at the cell temperature. Both  $\text{CO}_2$  laser beam and the probe HeNe laser beam are focused at the center of the cell by a ZnSe lens of 125 mm focal length and a glass lens of 250 mm focal length, respectively. The two laser beams are parallel and in the same horizontal plane. They are separated by a displacement  $r$  that is adjustable by an accurate translation platform carrying the HeNe laser and its focusing lens and the photodetector. The cell, the  $\text{CO}_2$  laser beam with the ZnSe focusing lens and the KRS-5 beam splitter are fixed in position. The horizontal geometry of the two laser beams is used to minimize any effects due to flow or convection, as indicated in Sell's work.<sup>8</sup> The HeNe laser beam emerging from the cell is transmitted through a quartz plate (which blocks the  $\text{CO}_2$  laser beam); after some suitable propagation distance, the defocused HeNe laser beam is incident on a small aperture which is positioned asymmetrically with respect to the probe beam cross section. This aperture is used<sup>11,12</sup> to convert a probe deflection into an intensity variation, which is monitored by a photodiode-amplifier assembly (UDT model 600). The photodiode signal  $S(r,t)$  is digitized by a Tektronix 7854 oscilloscope, which accumulates the signal and transmits it to a personal computer (IBM PC) via an IEEE 488 bus. The IBM PC stores the signal, prints it on a matrix printer, as well as generates theoretical signals to compare with the experimental ones.

The theoretical PTPD signal shape  $S(r,t)$  can be derived according to the work of Jackson *et al.*<sup>4</sup> In their Eq. (28), they show that a pulsed laser beam of Gaussian radius

a, energy  $E_0$  and pulse duration  $t_0$  produces a temperature gradient  $\partial T/\partial r$  in an infinite medium with weak absorption coefficient  $\alpha$  given by

$$\frac{\partial T}{\partial r} = \frac{-\alpha E_0}{2\pi k t_0 r} = \left[ \exp\left(\frac{-2r^2}{a^2 + 8Dt}\right) - \exp\left(\frac{-2r^2}{a^2 + 8D(t-t_0)}\right) \right] \quad (1)$$

for  $t > t_0$ . Here  $t$  is the time measured from the starting of the laser pulse and  $k$  is the thermal conductivity of the medium. The corresponding<sup>11</sup> probe deflection angle  $\phi(r,t)$  is

$$\phi(r,t) \approx \frac{\ell}{n_0} \frac{\partial n}{\partial T} \frac{\partial T(r,t)}{\partial r} \quad (2)$$

where  $\ell$  the interaction path length ( $\approx 1.8$  cm in our experiment),  $n_0$  is the ambient refractive index of the gas and  $\partial n/\partial T$  is the temperature coefficient of the refractive index. The observed signal at the photodiode is (for small deflection angles)

$$S(r,t) = G I_p'(r_1) L \phi(r,t) \quad (3)$$

where  $G$  is a constant depending on the photodiode sensitivity and gain,  $I_p'(r_1)$  is the lateral spatial derivative of the probe beam intensity distribution at the aperture position  $r_1$  and  $L$  is the "lever arm" of the probe beam (*i.e.*, distance from the cell center to the aperture and is about 22 cm in our experiment). Combining Eqs. (1)-(3), we have

$$S(r,t) = K \frac{\alpha E_0}{r} \left[ \exp\left(\frac{-2r^2}{a^2 + 8Dt}\right) - \exp\left(\frac{-2r^2}{a^2 + 8D(t-t_0)}\right) \right] \quad (4)$$

where

$$K = - \frac{1}{2\pi k t_0} \frac{\ell}{n_0} \frac{\partial n}{\partial T} G I_p'(r_1) L \quad (5)$$

is independent of  $t$  and  $r$ . Equation (4) is valid for  $t > t_0$ , and is the basis of pulsed PTPD measurement. It shows that  $\alpha$  can be measured as a function of excitation wavelength, as

done in previous PTPD measurements.<sup>1-9</sup> It also shows that  $D$  can be measured by fitting the observed signal shape  $S(r,t)$  to the form in the square bracket in Eq. (4), as done in the present work.

Our signal observed on the oscilloscope for  $x=0.126$  cm and cell temperature  $T_c=25^\circ\text{C}$  is shown in Fig. 2. Here, we see that the photodiode signal has a fast component and a slow component. The fast component is not appreciably delayed from the laser pulse on the scope time scale of 1 ms/div; this component is due to the acoustic RIG probe-beam deflection effect,<sup>10-12</sup> which occurs at a time delay of about 4.2  $\mu\text{sec}$  from the laser pulse for a sound speed of  $3 \times 10^4$  cm/sec. The signal variation after the initial sharp spike is due to the thermal RIG and follows the shape indicated in Eq. (4).

The signals averaged for 100 laser shots stored in the computer for two cell temperatures  $T_c$  are shown in Fig. 3. The signal magnitude is observed to decrease as temperature increases, in accordance with Eq. (2), since  $\partial n / \partial T$  goes as  $T^{-2}$  for an ideal gas. We clearly see that the signal peak moves to earlier times as temperature increases, indicating that thermal diffusivity  $D$  increases with temperature. By fitting Eq. (4) to the observed signals, we can obtain the theoretical signals shown in Fig. 3 with the values of  $D_{\text{fit}}$  as indicated. These theoretical curves are calculated with the following parameters: laser pulse width=150  $\mu\text{sec}$ , excitation beam Gaussian radius=0.07 cm, and separation between excitation and probe beam=0.105 cm. In reality, the excitation beam is not Gaussian but has annular structures, so that the theoretical fits are not perfect.

Table 1 indicates some of our experimental results for a range of cell temperature  $T_c$ . The fitted diffusivity values  $D_{\text{fit}}$  increases very substantially with temperature. The dependence of thermal diffusivity on temperature for  $\text{N}_2$  at 1 atmosphere has been

extensively measured in the literature,<sup>13-17</sup> generally with the use of wires or probes inserted into the gas. Using the diffusivity data listed by Rutherford *et al.*<sup>13</sup> (which is consistent with data from other workers), we can convert the measured  $D_{\text{fit}}$  in Table 1 into corresponding averaged gas temperature  $\bar{T}_g$ . We see that  $\bar{T}_g$  is generally somewhat cooler than the cell body temperature  $T_c$ . This is probably due to cooling effects occurring at the windows.

In conclusion, we have demonstrated a noncontact pulsed PTPD measurement in an unconfined hot gas for monitoring thermal diffusivity or the related temperature. The observed signal shape  $S(r,t)$  agrees well with the theoretical form of Jackson *et al.*<sup>4</sup> Such a nonintrusive method should be valuable for measurements *in situ* in open medium like flames or in other hostile environments.

#### ACKNOWLEDGMENTS

This work is supported in part by the Office of Naval Research. We thank Dr. A. C. Boccara and Dr. D. Fournier for very helpful discussions.

Table 1

Cell Temperature, Fitted Thermal Diffusivity  
From the Signal and the Corresponding Average  
Gas Temperature Based on Literature (Ref. 13)

$\bar{T}_c(^{\circ}\text{C})$	$D_{\text{fit}} (\text{cm}^2/\text{sec})$	$\bar{T}_g(^{\circ}\text{C})$
25	0.21	25
48	0.230	42
79	0.258	64
131	0.32	110
155	0.369	141
222	0.47	205
233	0.498	221
312	0.574	267
423	0.810	386

## REFERENCES

1. A. C. Boccara, D. Fournier and J. Badoz, *Appl. Phys. Lett.* **36**, 130 (1980).
2. D. Fournier, A. C. Boccara, N. M. Amer and R. Gerlach, *Appl. Phys. Lett.* **37**, 519 (1980).
3. A. C. Boccara, D. Fournier, W. Jackson and N. M. Amer, *Opt. Lett.* **5**, 377 (1980).
4. W. B. Jackson, N. M. Amer, A. C. Boccara and D. Fournier, *Appl. Opt.* **20**, 1333 (1981).
5. O. Benchikh, D. Fournier, A. C. Boccara and J. Teixeira, "Photothermal Measurement of Supercooled Water Thermal Conductivity," preprint.
6. M. A. Olmstead, N. M. Amer, S. Kohn, D. Fournier and A. C. Boccara, *Appl. Phys. A32*, 141 (1983).
7. M. A. Olmstead and N. M. Amer, *Phys. Rev. Lett.* **52**, 1148 (1984).
8. J. A. Sell, *Appl. Opt.* **23**, 1586 (1984).
9. A. Rose, J. D. Pyrum, C. Muzny, G. J. Salamo and R. Gupta, *Appl. Opt.* **21**, 2663 (1982).
10. W. Zapka, P. Poknowsky and A. C. Tam, *Opt. Lett.* **7**, 477 (1982).
11. B. Sullivan and A. C. Tam, *J. Acoust. Soc. Am.* **75**, 437 (1984).
12. A. C. Tam and W. P. Leung, *Phys. Rev. Lett.* **53**, 560 (1984).
13. W. M. Rutherford, W. J. Roos and K. J. Kaminski, *J. Chem. Phys.* **50**, 5359 (1969).
14. Y. S. Touloukian, P. E. Liley and S. C. Saxena, "Thermal Conductivity: Nonmetallic Liquids and Gases," Plenum, N. Y., 1970.
15. S. H. P. Chen and S. C. Saxena, *High Temp. Sci.* **5**, 206 (1973).
16. J. W. Haarman, AIP Conference Proc. No. 11, Edited by J. Kestin, American Instit. of Phys. N. Y., 1973, p. 193.
17. R. M. Thomson, *J. Phys. D: Appl. Phys.* **11**, 2509 (1978).






Figure 1. Experimental arrangement.




Figure 2. The upper oscilloscope trace shows the  $\text{CO}_2$  laser pulse shape, and the lower trace shows the observed photothermal deflection signal for  $\text{N}_2$  at  $25^\circ\text{C}$  for beam separation  $r=0.105$  cm. Horizontal scale is 2 ms/div.




Figure 3. Observed photothermal deflection signal at two different temperatures. (a)  $T_c = 25^\circ$ , (c)  $T_c = 157^\circ\text{C}$  for beam separation  $r = 0.105 \text{ cm}$ , as compared to the theoretical deflection signals using the fitted values of thermal diffusivity (b)  $D_{\text{fit}} = 0.21 \text{ cm}^2/\text{sec}$ , (d)  $D_{\text{fit}} = 0.369 \text{ cm}^2/\text{sec}$ .




Figure 4. Measure "mean" gas temperature ( $\bar{T}_g$ ) based on the values of  $D_{fit}$  as a function of cell temperature  $T_c$  given by a thermocouple. The dotted line indicates the case when the gas column being monitored is of uniform temperature at  $T_c$ .